



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK108	5.6	Upright	SR	Fusible	1/2	Brass, Polyester	165, 220, 286 (74, 104, 141)
VK110	5.6	Pendent	SR	Fusible	1/2	Brass, Polyester	165, 220, 286 (74, 104, 141)
VK110	5.6	Rack Storage Pendent	SR	Fusible	1/2	Brass	165, 220, 286 (74, 104, 141)
VK552	5.6	Rack Storage Upright	SR	Fusible	1/2	Brass	165, 220, 286 (74, 104, 141)

Prepared for: The Viking Corporation 210 North Industrial Park Drive
Hastings, MI 49058 USA

Manufacturing Location: The Viking Corporation 210 North Industrial Park Drive
Hastings, MI 49058 USA

FM Approvals Class: 2016, 2017, 2005
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3050241

Approval Granted: November 18, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in black ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
AVP, Approvals Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA