



# Certificate of Compliance

This certificate is issued for the following equipment:

| Model | K   | Type                         | Resp. | Element | NPT (in.) | Finishes | Temperature Ratings °F (°C)  |
|-------|-----|------------------------------|-------|---------|-----------|----------|------------------------------|
| VK112 | 5.6 | Horizontal Sidewall          | SR    | Fusible | 1/2       | Brass    | 165, 220, 286 (74, 104, 141) |
| VK112 | 5.6 | Recessed Horizontal Sidewall | SR    | Fusible | 1/2       | Brass    | 165, 220 (74, 104)           |
| VK206 | 8.0 | Pendent                      | SR    | Fusible | 3/4       | Brass    | 165, 220, 286 (74, 104, 141) |
| VK206 | 8.0 | Rack Storage Pendent         | SR    | Fusible | 3/4       | Brass    | 165, 220, 286 (74, 104, 141) |

Prepared for: The Viking Corporation 210 North Industrial Park Drive  
Hastings, MI 49058 USA

Manufacturing Location: The Viking Corporation 210 North Industrial Park Drive  
Hastings, MI 49058 USA

FM Approvals Class: 2001, 2012, 2015, 2005  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3050241

Approval Granted: November 18, 2015

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller  
AVP, Approvals Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA

