

## **Certificate of Compliance**

This certificate is issued for the following equipment:

## **Automatic Control Mode Sprinklers for Fire Protection**

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK506	22.4	Pendent	QR (ESFR)	Fusible	1	Brass	165, 205 (74, 96)
VK510	25.2	Pendent	QR (ESFR)	Fusible	1	Brass	165, 205 (74, 96)
VK592	19.6	Pendent	SR	Fusible	1	Brass	160, 205 (71, 96)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings,

MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings,

MI 49058, USA

FM Approvals Class: 2026, 2028, 2036

FM Approval Standard: Class Series 2000 (February 2018) and Class Series 2008 (February 2018)

Approval Identification: 3059911 Approval Granted: August 30, 2018

To verify the availability of the Approved product, please refer to <a href="www.approvalguide.com">www.approvalguide.com</a>

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



Member of the FM Global Group



## **Certificate of Compliance**

This certificate is issued for the following equipment:

## **Automatic Control Mode Sprinklers for Fire Protection**

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK506	22.4	Pendent	QR (ESFR)	Fusible	1	Brass	165, 205 (74, 96)
VK510	25.2	Pendent	QR (ESFR)	Fusible	1	Brass	165, 205 (74, 96)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings,

MI 49058, USA

Manufacturing Location: The Viking Corporation, 11305 James Street, Holland, MI 49424,

USA

FM Approvals Class: 2026, 2028

FM Approval Standard: Class Series 2008 (February 2018)

Approval Identification: 3059911 Approval Granted: August 30, 2018

To verify the availability of the Approved product, please refer to  $\underline{www.approvalguide.com}$ 

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



Member of the FM Global Group