



Sprinklers | Storage Sprinklers | Quick Response Storage Sprinklers

VK512 *

Details

Category	Quick Response Storage Sprinklers
Class of Work	2026 - AS Suppr Md (nom K = 25.2)
Approval Standard	FM 2008 - Quick Response Storage Sprinklers for Fire Protection
Certification Type	FM Approved and CPR("CE")
K	25.2
K (metric)	360
Coverage Type	Standard
Type	Dry Pendent
Response	QR - Quick Response
Element	Fusible
NPT (in.)	1 1/2
Finish	Brass, Electroless Nickel PTFE (ENT)
Temp. Rating (°F)	165, 205
Temp. Rating (°C)	74, 96
Sprinkler Category	Storage
Use with Vacuum System	No
Grooved Connection	Yes
Dry Sprinkler Min. Length, in.	8

Company

The Viking Corporation
5150 Beltway Dr SE, Caledonia ,
Michigan 49316
United States of America
<http://vikingcorp.com>

**Dry Sprinkler Min. Length, m** 0.2**Dry Sprinkler Max. Length, in.** 36**Dry Sprinkler Max. Length, m** 0.91**Listing Country** United States of
America

Footnote Reference * Approval of these dry sprinklers is limited to a minimum nominal length of 8 in. (0.20 m) and a maximum nominal length of 36 in. (0.91 m). Please note that the connection specified under the heading "NPT (in.)" in the table above are 1 1/2 inch NPT connection and 1 1/2 inch grooved connection.