



# Certificate of Compliance

This certificate is issued for the following:

**Model J-1 Alarm Check Valves**

Sizes: 3, 4, 6, and 8 inch NPS

(See table below)

**Prepared for:**

The Viking Corporation  
210 N Industrial Park Dr  
Hastings, MI 49058  
United States

**Manufactured at:**

The Viking Corporation  
210 N Industrial Park Dr  
Hastings, MI 49058  
United States

FM Approvals Class: 1041

Approval Identification: 0003042799

Approval Granted: September 15, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry  
to reduce property losses.*

A handwritten signature in black ink, reading "Richard B. Dunne".

Richard B. Dunne  
Group Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



*Member of the FM Global Group*



# Certificate of Compliance

Product Designation	Description	Nominal Pipe Size, in. (mm)	Maximum Working Pressure, psi (kPa)	Remarks
Model J-1	Alarm Check Valve, Flanged Ends	3, 4, 6, 8 (80, 100, 150, 200)	300 (2070)	a, b
Model J-1	Alarm Check Valve, Grooved Ends	3, 4, 6, 8 (80, 100, 150, 200)	300 (2070)	a, b
Model J-1	Alarm Check Valve, Flange x Grooved	3, 4, 6, 8 (80, 100, 150, 200)	300 (2070)	a, b

## Notes:

- a. Resilient Seat
- b. Approved for use with Model C-1 retard chamber.

